

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Unit 33 -	ine Floors 2 35 Captain Cook Drive ingbah NSW 2229			lssue Print		17-0062 22/11/2 23/11/2(Rigid Pla	017 017	
Sample Descri	ption Clients Ref : "Rigid P PVC Floor panels End Use : Floating Floo Nominal Composition : Nominal Mass per Unit An Nominal Thickness :	oring PVC/Calciur	n Carbonate 9800g/r					
AS 4586-2013 Appendix A	Slip Resistance Classific Wet Pendulum Test Metl		Pedestrian \$	Surface Mate	rials			
	Date of Test	Date of Test				22/11/2017		
	Test Temperature (20±5d	Test Temperature (20±5degC) 24 °C						
	Sample Preparation	Sample Preparation Washed with pH neutral detergent and dried						
	Test Direction	Test Direction Length						
	Fixed/Unfixed	Fixed/Unfixed Unfixed						
	Slider No 96 Batch No	Slider No 96 Batch No			72			
	Length	1	2	3	4	5	SRV	
	British Pendulum	43	44	44	43	43	43	
	Number Classification					Р	3	
		Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 02/09/2015 Slider prepared using P400 and 3µm lapping film.						
	flooring or paving materia	These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.						

