



WET PENDULUM SLIP RESISTANCE TEST SUMMARY

Tarkett Tapiflex Excellence 80

Prepared for: Paul Roberts
Tarkett Australia Pty Ltd
Suite 1, Level 3, 3 Columbia Court
BAULKHAM HILLS NSW 2153

Test Standard: AS 4586:2013 Slip resistance classification of new pedestrian surface materials, Appendix A - Wet Pendulum Test.

Test Location: Test Slip Australia Pty Ltd, Beaumont Hills, NSW.

Test Date: 7 October 2018

Test Equipment: Wessex Pendulum Skid Resistance Tester Serial Number SK1818, Calibrated 23/4/2018.


Slider Rubber: Slider 96 Batch No. #79 prepared on P400 & 3µm lapping film.

Test Personnel: Clark Ahearn

The test results for the product range tested are summarised in the table below. Please refer to referenced ATTAR Report No. for the specific slip resistance test information.

ATTAR Report No.	Specimen Description	Size (mm)	Wet Pendulum Test	
			Slip Resistance Value	Classification
13352.1	Tapiflex Excellence, Bille embossing, sheet vinyl,	2000x2000	38	P3
13352.4	Tapiflex Excellence, BOIS27 embossing, sheet vinyl	2000x2000	39	P3
13352.5	Tapiflex Excellence, KW1289 embossing, sheet vinyl	2000x2000	44	P3
13352.7	Tapiflex Excellence, Lumber embossing, sheet vinyl	2000x2000	39	P3

Prepared By:



Marcus Braché
Senior Engineering Technician

Reviewed By:



Dale Siegle
Compliance and Test Technician